

Aaron Carpenter

From: Ernst, Brian C. <Brian.Ernst@tvfr.com>
Sent: Wednesday, March 23, 2022 12:08 PM
To: Aaron Carpenter
Cc: Foster, Jeremy L.
Subject: TVFR SPL Request
Attachments: POA%20-%20341-Fire-Exh-C1.10.pdf

Hi Aaron,

I've reviewed your plan submittal and no TVFR permit will be required for this project. The proposed modifications to the parking area do not affect the building footprint, do not affect fire department access or aerial apparatus access, and it do not affect the fire department fire fighting water supply. Please submit this email with your land use application to the City of Beaverton. Please reach out directly if there are any questions. Thanks!

Brian Ernst
Deputy Fire Marshal/Fire Investigator
Tualatin Valley Fire Rescue